

Water Code: MTW01	Supplies: SUMMIT BULDING	Town: Sargent's Purchase
Park Code: 00209	Park: Mount Washington State Park	County: Coos

Year Built: 1985

Leased:

EPA ID #: 0927020

Water Source: Well

Cost Source:

Cost Type:

Condition Code:

Cost Type Other:

Plans:

Contract Number:

Well Depth: 800'

Feet of Casing: 77'

Static Level:

Tank Size: 450 GAL

Pump Specs BURK MODEL SNB26B SUBMERSIBLE 2HP
PUMP SET @ 625'

Original Cost: \$0.00

Replacement Cost: \$0.00

GPM: 12

Maintenance Cost: \$0.00

Pressure System:

Improvement Cost: \$0.00

Comments:

YTD Maintenance: \$0.00

YTD Improvement: \$0.00

Total Value: \$0.00

Water Code: MTW00	Supplies: SUMMER SYSTEM	Town: Sargent's Purchase
Park Code: 00209	Park: Mount Washington State Park	County: Coos

Year Built: 1985

Leased:

EPA ID #:

Water Source: Well

Cost Source:

Cost Type:

Condition Code:

Cost Type Other:

Plans:

Contract Number:

Well Depth: 800'

Feet of Casing: 77'

Static Level:

Tank Size: 2@20180EA

Pump Specs CRANE DEMING, 6602 MU6T, CENTRIFUGAL, 5

Original Cost: \$0.00

Replacement Cost: \$0.00

GPM: 12

Maintenance Cost: \$0.00

Pressure System:

Improvement Cost: \$0.00

Comments: SCALING IN BOTH TANKS. PUMPS ALTERNATE CYCLE. TANKS FILLED MANUALLY FROM WELL, FEEDS BUILDING AUTOMATICLY VIA

YTD Maintenance: \$0.00

YTD Improvement: \$0.00

Total Value: \$0.00

Water Code: MTW03 **Supplies:** WINTER SYSTEM IN SHERMAN ADA **Town:** Sargent's Purchase

Park Code: 00209 **Park:** Mount Washington State Park **County:** Coos

Year Built: 1985

Leased:

EPA ID #:

Cost Source:

Water Source: Well

Cost Type:

Condition Code:

Cost Type Other:

Plans:

Contract Number:

Well Depth: 800'

Feet of Casing: 77'

Static Level:

Tank Size: 452 GAL

Pump Specs

Original Cost: \$0.00

Replacement Cost: \$0.00

GPM: 12

Maintenance Cost: \$0.00

Pressure System: CHAMPION, BMB -5 SS, 1/2

Improvement Cost: \$0.00

Comments: SCALING IN TANK.AUTO CON CALLS FOR
 WATER TOBE PUMPED FROM PUMP VAULT
 TO PRESSURE TANK. WATER IS METERE

YTD Maintenance: \$0.00

YTD Improvement: \$0.00

Total Value: \$0.00

Water Code: MTW04

Supplies: 2ND STAGE OF WINTER SYSTEM

Town: Sargent's Purchase

Park Code: 00209

Park: Mount Washington State Park

County: Coos

Year Built: 1985

Leased:

EPA ID #:

Cost Source:

Water Source: Well

Cost Type:

Condition Code:

Cost Type Other:

Plans:

Contract Number:

Well Depth: 800'

Feet of Casing: 77'

Static Level:

Tank Size: 5@ 2538 EA

Pump Specs GOULDS, JO5 NS, J SERIES, 1/2.

Original Cost: \$0.00

Replacement Cost: \$0.00

Maintenance Cost: \$0.00

Improvement Cost: \$0.00

YTD Maintenance: \$0.00

YTD Improvement: \$0.00

Total Value: \$0.00

GPM: 12

Pressure System: WELL X TROLL, WX252, GAL. 87.

Comments: PITTING IN ALL TANKS. FIVE TANKS ARE FILLED MANUALLY FROM STATE WELL. THIS SYSTEM USED TO FEED ENTIRE BLDG IN